



Lake Valley Fire Protection District
Hydrant Flow Test Data

Date Submitted For Flow Testing

Test Date Test Time

Development Address

Distance To Flow Hydrant

Residual Hydrant

Residual Hydrant ID Make

Main Size Inch Residual Location

Flow Duration Minutes Tester

Gage #

Residual Hydrant - Residual Pressure: psi

Residual Hydrant - Static Pressure: psi

Projected Flow:
@ 20 psi gpm

Flow Hydrant

Make Flow Hydrant - Static Pressure: psi

Flow Location

Flowing Hydrant ID Pitot Gage #

Tip Diameter Reading psi

Outlet Coefficient Flow gpm

Remarks

**Call South Tahoe PUD at 530-544-6474 During Business Hours
or 530-543-6240 After Hours and Weekends
Prior to Flow Testing or Flushing Hydrants**

Lake Valley FPD Signature _____ Date _____