

**El Dorado County Development Services Department  
Building Services**

**POLICY**

*A department policy is based on an interpretation of a code provision  
and is subject to change based on information.*

**GAS PIPING TO ISLAND CABINET**

Where the installation of gas piping underground beneath buildings is unavoidable the piping shall be encased in an approved conduit designed to withstand the superimposed loads. The conduit shall extend into a normally usable and accessible portion of the building and, at the point where the conduit terminates in the building, the space between the conduit and the gas piping shall be sealed to prevent the possible entrance of a gas leakage. The conduit shall extend at least 4 inches outside the building, be vented above grade to the outside, and be installed so as to not permit the entrance of water and insects (CPC 1211.1.6).