

# EDC EMD UST Repair/Install Permit Requirement Matrix

Type of Work	Permitted Activity – Major (per tank)	Permitted Activity - Minor	No Permit Required
Tank Install	X		
Tank Removal	X		
Boot Replacement (Non VPH)		X - If change in type or design	X - If substituting like for like while an inspector is on-site
VPH Boot Replacement		X – Even if substituting like for like	
Cathodic Protection (anode replacement/ rewire)	X		
Dispenser Replacement		X	
Flex-Line Replacement (sump/UDC)		X	
Line Leak Detector		X - If change in device type or design	X - If substituting like for like while an inspector is on-site
Monitoring Console Install or Replacement (hardware)	X– Includes cold start		
Monitoring Console programming (software)		X - Includes cold start	
Overfill Prevention Equipment		X - If change in device type or design, or new install	X - If substituting like for like while an inspector is on-site
Repair UST Annular	X		
Sensor Replacement (Sumps, ATGs, UDCs)		X	X - If substituting like for like while an inspector is on-site
Spill Buckets (Direct Burial)		X – Soil sampling may be required	
Spill Buckets (Fill Sump)		X	X - If substituting like for like while an inspector is on-site
Sump Repair	X (Exterior)	X (Interior)	
Turbine repair		X – If retesting is needed	X - If substituting like for like while an inspector is on-site
UDC Replacement	X – Soil sampling may be required		
Underground Piping (any)	X		
Vacuum/Pressure/Hydraulic (VPH) System Repair (smart sensors, hoses, etc.)		X	X - If substituting like for like while an inspector is on-site

Drop-tube replacement		X	X - If substituting like for like while an inspector is on-site
Cold Start		X	
Turbine Replacement		X	
Installing new 208, 420, or other continuous electronic monitoring sensors (where new wiring to the monitoring panel is needed)	X		

\*Regardless of permitted activity, all UST installs/closures/modifications/repairs require a minimum 48-hour notification to EDC EMD.

\*\*If your UST install/closure/repair project does not fall under the “*Type of Work*” column mentioned above, please call (530) 621-5300 or email [emd.info@edcgov.us](mailto:emd.info@edcgov.us) for guidance.